

50%, 80%, 100%, and Maintenance Inspection Requirements

Inspections (50%, 80%, 100%)

I125

(Place this comment on the plans) Contact the Gwinnett County Fire Marshal's (Inspection Request Line) at (678) 518-6102 for inspections at 50%, 80% and 100% completion. NOTE: (50%) Inspection includes ALL NEW BUILDINGS COMING OUT OF THE GROUND and inspection of floor ceiling penetrations. (80%) Inspection of any fire rated barriers, floor or ceiling. (100%) Final inspection: all systems, equipment installed and operating, ready for occupancy. The inspection request must be phoned in before 2:00pm the day prior to the date the inspection is needed.

Inspections (80%,100%)

I130

(Place this comment on the plans) Contact the Gwinnett County Fire Marshal's (Inspection Request Line) at (678) 518-6102 for inspections at (80%) and (100%) completion. NOTE: (80%) = Inspection of any fire rated barriers, floor or ceiling. (100%) = Final inspection: all systems, equipment installed and operating, ready for occupancy. The inspection request must be phoned in before 2:00pm the day prior to the date the inspection is needed.

Inspections (100%)

I135

(Place this comment on the plans) Contact the Gwinnett County Fire Marshal's (Inspection Request Line) at (678) 518-6102) for a (100%) Inspection. (100%) = Final Inspection: All systems, Equipment installed & Operating; ready for occupancy. The inspection request must be phoned in before 2:00pm the day prior to the date the inspection is needed.

Revised 9/04