


NOTES:

1. SUBGRADE TO BE COMPACTED TO 95% MAX. DRY DENSITY PER STANDARD PROCTOR.
2. REINFORCEMENT STEEL SHALL BE PLACED TO ALLOW A MIN. OF 1 1/2" COVER, EXCEPT WHERE NOTED.
3. REINFORCEMENT STEEL SHALL BE OF INTERMEDIATE GRADE AND SHALL CONSIST OF NO. 4 @ 6" O.C. E.W.
4. ALL CONCRETE SHALL BE CLASS AA1 4500 PSI.
5. WHEN 60" & 72" BASE SECTIONS ARE REQUIRED, AN ADAPTER SECTION SHALL BE USED IN CONJUNCTION WITH THE STANDARD CONE.
6. CONCRETE TOP COVER THICKNESS: 8" - VEHICULAR TRAFFIC AREAS.



GWINNETT COUNTY
DEPARTMENT OF PLANNING & DEVELOPMENT
STANDARD DRAWING

Standard Round Precast Drop Inlet

DATE: JANUARY 1988

SHEET: 610