



gwinnettcounty

75 Langley Drive • Lawrenceville, GA 30046-6935
(tel) 770.822.8720 • (fax) 770.822.8735

November 3, 2015

**ADDENDUM #1
BL130-15**

HVAC System Maintenance Services at Various County Facilities on an Annual Contract

This addendum is being issued to answer questions received and provide clarification.

Q1. On page 14 regarding proper air filter disposal for the Police Training Facility, what sort of certification is required to show a vendor can properly dispose of air filters removed from this site? What are the specific requirements to be in compliance with this requirement?

A1. Refer to Item C, page 4. The certification needs to indicate that they are licensed to haul and dispose of this type of lead waste.

Q2. On page three, the scope of work indicates that every belt should be changes no less than twice per year. This seems to be double the industry standard of 1x/year. Can you confirm that this is correct?

A2. The specifications are correct.

Q3. For the Bi-Monthly filter changes at the Police Training Academy, do you mean twice a month or every 2 months?

A3. Bi-Monthly is every 2 months.

Q4. Are there specific products that cannot be used?

A4. Products containing rodenticide are prohibited for use in Sections B and I.

Q5. Who is the incumbent on the previous procurement?

A5. United Maintenance

Q6. How many PIUs at the DOT Maintenance & Supply? Police Training Complex?

A6. DOT Maintenance & Supply has 38 PIUs
Police Training Complex has 19 PIUs

Q7. How many exhaust fans are at Grayson Library? Dacula Library?

A7. Grayson Library and Dacula Library both have 3 exhaust fans.

ADDITIONS/REVISIONS

Revised equipment list is attached. NOTE: Facilities modified are Gwinnett County Police Headquarters and Gwinnett Senior Services Center.

Please make the following change:

Change FROM: Bids will be received until **2:50 p.m. Thursday, November 5, 2015.**

Change TO: Bids will be received until **2:50 p.m. Monday, November 9, 2015.**

Please replace Page 21 of the bid document with the attached Revised Bid Schedule, Page 21R.

This addendum should be signed in the space provided below and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Company Name _____

Authorized Representative _____

Thank you.
Marlo Puckett
Purchasing Associate II



BID SCHEDULE

Item #	Locations	Quarterly Charge	Monthly Charge	Annual Charge
47.	“Brown” Radio Tower 1850 N. Brown Road Lawrenceville, GA 30043-8120			
48.	“Tribble” Radio Tower 2568 Chandler Road, SE Lawrenceville, GA 30045			
49.	“Goshen” Radio Tower 5878 Goshen Springs Road Norcross, GA 30071-3509			
50.	“Lanier Mountain” Radio Tower 2286 Highpoint Road Snellville, GA 30078-3144			
51.	“Tuggle” Radio Tower 3800 Tuggle Road Buford, GA 30519-4039			
52.	“Water Park” Radio Tower 2601 Buford Dam Road Buford, GA 30518-2040			
53.	“Norris Lake” Radio Tower 4663 Anderson Livsey Lane Snellville, GA 30039-2706			
54.	“Crooked Creek” Radio Tower 6556 Plant Drive Norcross, GA 30092-2234			
55.	“Fire Station No. 10” Radio Tower 3680 Old Atlanta Rd Suwanee, GA 30024-1172			
56.	“Headquarters” Radio Tower 770 Hi Hope Road Lawrenceville, GA 30043-4540			
57.	Gwinnett Senior Services Center 567 Swanson Drive Lawrenceville, GA 30043			
58.	Elizabeth Williams (Snellville) Branch Library 2740 Lenora Church Road Snellville, GA 30078			
TOTAL ANNUAL COSTS				\$

Company Name: _____

EQUIPMENT INVENTORY

Collins Hill Branch Library
455 Camp Perrin Road
Lawrenceville, GA 30043

AHU#1A	LENNOX	80UHG4/5-120A-2	6398L07778	1-16X25X1
AHU#1B	LENNOX	80UHG4/5-120A-2	6398K12605	1-16X25X1
CU-1	LENNOX	LSA120C-1Y	5699C04690	
COIL	MAGIC AIRE	VW/VX-10	741-250	
AHU#2A	LENNOX	80UHG4/5-120A-2	6398L07778	1-16X25X1
AHU#2B	LENNOX	80UHG4/5-120A-2	6398K12605	1-16X25X1
CU-2	LENNOX	LSA090C-1Y	5699C04690	
COIL	MAGIC AIRE	VW/VX-7.5	741100 05140	
AHU#3	LENNOX	80UHG3-75A-2	6398L 21441	1-16X25X1
CU-3	LENNOX	H529-036-9Y	58996 37384	
COIL	LENNOX	BV12436-10N2IVER	K98-122447	
AHU#4	LENNOX	80UHG3-75A-2	6398L 21429	1-16X25X1
CU-4	LENNOX	H529-042-9Y	5899C39563	
COIL	LENNOX	BV12442-23N38VER	K98-2977	
AHU#5	LENNOX	80MGF4/5-140A-11	6398K 17256	1-16X25X1
CU-5	LENNOX	H529-060-9Y	5899B 11416	
COIL	LENNOX	BV73060-19N12VER5	K98-12444	
AHU#6	LENNOX	80MGF4/5-140A-11	6398K 172564	1-16X25X1
CU-6	LENNOX	H529-060-9Y	5899B 11416	
COIL	LENNOX	BV73060-19N12VER5	J98-1776	

AHU#7	LENNOX	ML1800VH110P48C-53	1715A02933	1-6X25X1
CU-7	LENNOX	TSA060S4N44Y	5815G07528	
COIL	LENNOX	CX34-49C-6F1	6015G39487	
AHU#8A	LENNOX	80UHG4/5-120A-2	6398K 12593	1-16X25X1
AHU#8B	LENNOX	80UHG4/5-120A-2	6398K 12593	1-16X25X1
CU-8	LENNOX	LSA120C-1Y	5699C09088	
COIL	MAGIC AIRE	VW/VX-10	741250	
AHU#9	LENNOX	80UHG3-75A-2	6398L21431	1-16X25X1
CU-9	LENNOX	H529-042-98Y	5899C	
COIL	LENNOX	BV12442-23N38VER	K98-2979	
AHU#10	LENNOX	80UHG3-75A-2	6398L21432	1-16X25X1
CU-10	LENNOX	H529-042-98Y	5899C39556	
COIL	LENNOX	BV12442-23N38VER	K98-3024	
AHU#11	LENNOX	80UHG2-75A-1	6398F 13458	1-16X25X1
CU-11	LENNOX	H529-018-IP	58990 33096	
COIL	LENNOX	BV12424-10N7VER2	L98-1272	

Lawrenceville Branch Library and
 Headquarters 1001 Lawrenceville Highway
 Lawrenceville, GA 30045

RTU #1	LENNOX	GCS16-240-235-1Y		9 - 16X25X2 2 - A80
RTU #2	LENNOX	TGA120S2BM		4 - 16X25X2 1 - A51
RTU #3	LENNOX	GCS16-048-120-6Y		1 - 20X25X2
RTU #4	LENNOX	GCS16-090-200-2Y		4 - 20X25X2 1 - A53
RTU #5	LENNOX	GCS16-090-200-2Y		4 - 20X25X2 1 - A53
RTU #6	LENNOX	TGA150S2BM		4 - 16X20X2 1 - A46
RTU #7	LENNOX	TGA150S2BM		4 - 16X20X2 1 - A46
RTU #8	TRANE	2 TON PACKAGE	NA	NA
AHU#1	LENNOX	3 TON SPLIT		1 - 20X25X1
CU#1	LENNOX	HS 18-513-5Y	5189J12755	
AHU#2	LIEBERT	CU066A-C00	148327A	2-18X24X2
CU#2	LIEBERT	CSF 086P	89080487	
AHU#3	LIEBERT	BU067A-CAEI	NA	2-25X25X2
CU#3	LIEBERT	CSF 083P	NA	
EF#1		ROOF		

EF#2 ROOF

EF#3 ROOF

RTU #9 TRANE 4 TON GAS ELEC 2-10X20X2
2-20X20X2

TOTAL FILTER LIST: 20-18X24X2
8-16X20X2
2-20X25X2
2-16X30X2
2-20X20X1

Peachtree Corners Branch Library
5570 Spalding Drive
Norcross, GA 30092-2501

AHU#1	CARRIER	40RR-028-007	96486	
CU-1	CARRIER	NA	NA	2-B85 Belts
AHU#2	CARRIER	40RR-016-037	R888062	
CU-2	CARRIER	38AQS016-5	S2699F31031	1-A43 Belt
RTU#3	CARRIER	50TFQ005-A-5	NA	
EF#1	PENN	AB35		1-4L170 Belt
EF#2	PENN	AB35		1-4L160 Belt

Filters: 5-16x25x2
9-20x25x2
2-16x20x2

Duluth Branch Library
3480 Duluth Park Lane
Duluth, GA 30096-3257

AHU#1	CARRIER	40RR-024-020	Y880708	3-20X25X2 3-16X25X2
CU#1	CARRIER	38AKS016-510	2499F27024	
AHU#2	CARRIER	40RR-016-030	X887208	3-20X25X2 3-16X25X2
CU#2	CARRIER	38AE-016-500	X887562	
HEATER 1	REZNOR	HX350-6-E	ANL62 J8N77685	
HEATER 2	REZNOR	X250-8	AXL31 K6N27260	

Norcross Branch Library
6025 Buford Highway
Norcross, GA 30071

AHU#1	CARRIER	40QBS060320	3789H05886	1-20X25X1
CU#1	CARRIER	38YG060600	3989E31527	
AHU#2	CARRIER	39ED17	8925T19153	4-12X24X2 3-24X24X2
CU#2A	CARRIER	38AQS012-6	3102F69583	
CU#2B	CARRIER	38AQS012-6	2902F66462	
EF#1		BATH		
EF#2		BATH		

Buford & Sugar Hill Branch Library
2100 Buford Highway
Buford, GA 30518

AHU#1	CARRIER	40QBS060320	3789H05886	1-20X25X1
CU#1	CARRIER	38YG060600	3989E31527	
AHU#2	CARRIER	39ED17	8925T19153	4-12X24X2 3-24X24X2
CU#2A	CARRIER	38AQS012-6	3102F69583	
CU#2B	CARRIER	38AQS012-6	2902F66462	
EF#1		BATH		
EF#2		BATH		

Suwanee Branch Library
361 Main Street
Suwanee, GA 30024

FC#1	LENNOX	G24-200A-1	6304B01450	2024X24X2
CU#1	LENNOX	HS29-090-3Y	5603D03862	1-A51 BELT
FC#2	LENNOX	G50UH-60C110-04	5803C 32946	1-16X25-2
CU#2	LENNOX	HSO29-048-10Y	5804E27858	
FC#3	LENNOX	G50UH-24A-045-07	5804A 44677	1-16X25-2
CU#3	LENNOX	HS29-036-9Y	5804E25117	
FC#4	LENNOX	G50UH-60D-155-05	5803J 21820	1-20X25-2
CU#4	LENNOX	HS29-036-9Y	5804E21134	
FC#5	LENNOX	G50UH-24A-045-07	5804A 44674	1-16X25-2
CU#5	LENNOX	HS29-048-10Y	5804E25056	
FC#6	LENNOX	G50UH-48C-110-07	5804A 44677	1-16X25-2
CU#6	LENNOX	HS29-036-9Y	5804B29645	
FC#7	LENNOX	G50UH-60D-155-05	5803J 21818	1-20X25-2
CU#7	LENNOX	HS29-060-10Y	5804E21126	
RTU#1	LENNOX	LGA120AH2BSY	5604B07273	4-18X24X2 1-A46 BELT
RTU#2	LENNOX	LGA060H2BSY	5604B07450	2-16X25X2 1-A46 BELT
RTU#3	LENNOX	LGA060H2BSY	5604B07451	2-16X25X2 1-A43 BELT
RTU#4	LENNOX	LGA090H2BSY	5604B07264	4-18X24X2 1-A46 BELT
EF#1	GREENHECK	6-131-BX-QD	04D24223	

EF#2	GREENHECK	G-080-DGEX-QD	04D20885
EF#3	GREENHECK	G-808-DGEX-QD	04D20884
EF#4	GREENHECK	G-085-DGEX-QD	04D227248
DSFU#1	EMI	CAH24030000C	1-03-L-6205-48
DSCU#1	EMI	SHC18DF00000A	1-04-D-9238-19

Mountain Park Branch Library
1210 Pounds Road, SW
Lilburn, GA 30047-6744

AHU#1	CARRIER	40PRO16540	5696857	4-16X20X2 4-20X20X2
CU#1	CARRIER	38AQS016-530	2100F050045	
AHU#2	CARRIER	40QB060300	1487A21246	1-20X25X1
CU#2	BRYANT	661CJ060-C	2105E23223	
AHU#3	CARRIER	40AQ024300AC	2987A10664	2-16X20X1
CU#3	CARRIER	38QN024310	3187E68512	

Lilburn Branch Library
788 Hillcrest Road, NW
Lilburn, GA 30047

AHU#1	CARRIER	40RR-016-030	Z793296	4-20X20X2 4-16X20X2
CU#1	CARRIER	38AQ5016-530	2100F050446	2-A43 BELTS
AHU#2	TEMPSTAR	NFCP000A1	L970747123	1-20X25X1
CU#2	CARRIER	38YCC060560	0704E21307	

Elizabeth Williams (Snellville) Branch
Library 2740 Lenora Church Road
Snellville, GA 30078

AHU#1	CARRIER	40RR-016-030	X795949	4-20X20X2 4-16X20X2
CU#1	CARRIER	38AQS5016-530	4400F42270	2-A43 BELTS
AHU#2	CARRIER	400B060300	4986A22665	1-20X25X1
CU#2	CARRIER	38YG060500	3591E1015	
AHU#3	TEMPSTAR	NFCP4800A1	L971837647	1-20X25X1
CU#3	TEMPSTAR	CH5548VHC2		

Centerville Branch Library and Community
Center 33025 Bethany Church Road
Snellville, GA 30039-6109

AHU#1	TRANE	TWE024C140B0	2152AF62V	1-20X20X1
CU#1	TRANE	TTB024C100A2	Z26RJMBF	
AHU#2	TRANE	TWE024C140B0	2152AFVH2V	1-20X20X1
CU#2	TRANE	TTB024C100A2	Z162RL9BF	
AHU#3	TRANE	TWE030C140B0	Z2813C1L2V	1-20X22X2
CU#3	TRANE	TTA030C300A2	Z2621YK3F	
AHU#4	TRANE	TWE048C140C0	2265UU92V	1-20X22X2
CU#4	TRANE	TTA048D300A0	Z2920GF3F	
AHU#5	TRANE	TWE030C140B0	2152AF62V	1-20X24X2
CU#5	TRANE	TTB030C100A2	Z292NEBF	
AHU#6	TRANE	TWE030C140B0	Z2813JE2V	1-20X22X2
CU#6	TRANE	TTB030C100A2	Z292KH1BF	
AHU#7	TRANE	TWE090C140B0	Z2740XL5H	2-16X20X2
CU#7	TRANE	TTA090A300DA	R411BAAH	
AHU#8	TRANE	TWE024C140B0	Z152AFF2V	1-20X20X2
CU#8	TRANE	TTB024C100A2	Z263P9RBF	
AHU#9	TRANE	TWE024C140B0	Z152AFF2V	1-20X20X2
CU#9	TRANE	TTB018C100A	Z292KKTBF	
AHU#10	TRANE	TWE030C140B0	Z2813UY2V	1-20X20X2
CU#10	TRANE	TTB030C100A2	Z292KKTBF	
AHU11	TRANE	TWE090A300CA	Z2740LH35H	2-16X20X2
CU#11	TRANE	TTA090A300DA	R412N2AAH	

AHU#12	TRANE	TTWE018C140B0	Z281T1U2V	1-20X20X1
CU#12	TRANE	TTB018C100A2	Z2927H4BF	
AHU#13	TRANE	TTWE042C140C0	Z2857862V	1-20X24X2
CU#13	TRANE	TTA042D300B0	Z292PTT3F	
AHU#14	TRANE	TWE090A300CA	NA	1-16X22X2
CU#14	TRANE	TTA090A300DA	R472538AH	1-16X20X2
AHU#15	TRANE	TWE048C140C0	Z254TON1V	1-20X22X2
CU#15	TRANE	TTA048D300A0	Z290D13F	
AHU#16	TRANE	TTWE042C140C0	3292LC21V	1-20X22X2
CU#16	TRANE	2TTR036A1000AA	314258B3F	
AHU#17	TRANE	TWE048C0	33265CF2V	1-20X22X2
CU#17	TRANE	2TTR2048A1000A	32557SP3F	

Grayson Branch Library
700 Grayson Parkway
Grayson, GA 30017

AHU#1	TRANE	2TEC3F60A1000AA	62535P82V	1-20X25X2
CU#1	TRANE	2TTB3060A1000AA	61370D51F	
AHU#2	TRANE	2TEC3F60A1000AA	62337D2V	1-20X25X2
CU#2	TRANE	2TTB3060A1000AA	619450W1F	
AHU#3	TRANE	2TEC3F48A1000AA	6251H6X2V	1-20X25X2
CU#3	TRANE	2TTB3048A1000AA	62015PN4F	
AHU#4	TRANE	2TEC3F60A1000AA	623365R2V	1-20X25X2
CU#4	TRANE	2TTB3060A1000AA	61310WD1F	
AHU#5	TRANE	2TEC3F18A1000AA	62925B62V	1-20X25X2
CU#5	TRANE	2TTB3018A1000AA	60214M55F	
AHU#6	TRANE	2TEC3F60A1000AA	6251KDM2V	1-20X25X2
CU#6	TRANE	2TTB3060A1000AA	6273MD41F	
AHU#7	TRANE	2TEC3F60A1000AA	622705W2V	2-16X25X2
CU#7	TRANE	2TTB3060A1000AA	612K1N1F	
AHU#8	TRANE	2TEC3F60A1000AA	62535RH2V	1-20X25X2
CU#8	TRANE	2TTB3060A1000AA	61056FE1F	
AHU#9	TRANE	2TEC3F60A1000AA	62535P62V	1-20X25X2
CU#9	TRANE	2TTB3060A1000AA	6282LSS1F	
AHU#10		MINI SPLIT	WASHABLE	FILTER
AHU11	TRANE	2TEC3F60A1000AA	62535P92V	2-16X25X2
CU#11	TRANE	2TTB3030A1000AA	618259W2F	

AHU#12	TRANE	2TEC3F60A1000AA	62271FY2V	1-20X25X1
CU#12	TRANE	2TTB3060A1000AA	6284TGE1F	
AHU#13	TRANE	2TEC3F60A1000AA	6253MUS1V	1-20X25X2
CU#13	TRANE	2TTB3060A1000AA	61825552F	

Dacula Branch Library
265 Dacula Road
Dacula, GA 30019

AHU#1	TRANE	TWE060P130B0	535326S2V	1-20X25X2
CU#1	TRANE	2TTR2060B1000AA	5332T602F	
AHU#2	TRANE	TWE048P130B0	NA	1-20X25X2
CU#2	TRANE	2TTB2048A1000AA	5082K343F	
AHU#3	TRANE	TWE048P130B0	5374KWA1V	1-20X25X2
CU#3	TRANE	2TTB3048A1000AA	54045HA3F	
AHU#4	TRANE	TWE060P130B0	535323A2V	1-20X25X2
CU#4	TRANE	2TTR2060B1000AA	424481A2F	
AHU#5	TRANE	TWE018P130B0	5363YHP2V	1-20X25X2
CU#5	TRANE	2TTB3018A1000AA	5441TYC5F	
AHU#6	TRANE	TWE060P130B0	5324WK52V	1-20X25X2
CU#6	TRANE	2TTR2060B1000AA	5304RAW2F	
AHU#7	TRANE	TWE048P130B0	5374KU91V	2-16X25X2
CU#7	TRANE	2TTB2048A1000AA	5295SE63F	
AHU#8	TRANE	TWE060P130B0	62535RH2V	1-20X25X2
CU#8	TRANE	2TTB2060A1000AA	537302P3F	
AHU#9	TRANE	TWE060P130B0	535323B2V	1-20X25X2
CU#9	TRANE	2TTB2060A1000AA	5022W7T3F	
AHU#10		MINI SPLIT	WASHABLE	FILTER
AHU11	TRANE	TWE060P130B0	5324WJY2V	2-16X25X2
CU#11	TRANE	2TTR2060B1000AA	50646LR2F	

AHU#12	TRANE	TWE060P130B0	533457X2V	1-20X25X1
CU#12	TRANE	2TTR2060B1000AA	53445ED2F	
AHU#13	TRANE	TWE060P130B0	5245NYK2V	1-20X25X2
CU#13	TRANE	2TTR2060B1000AA	5352RSP2F	

Five Forks Branch Library
2780 Five Forks Trickum Road
Lawrenceville, GA 30044

AHU#1	CARRIER	40BA009300	1394F89531	2-20X25X2
CU#1	CARRIER	38BQ008530	2294G00225	1-4L620 BELT
AHU#2A	CARRIER	FN4BNF060	4503A70706	1-24X24X2
CU#2A	CARRIER	38YCC060560	1404E28672	
AHU#2B	CARRIER	FB4BNFNF036	1804A83717	1-16X24X2
CU#2B	CARRIER	38YC036550	1304E03203	
AHU#3	CARRIER	40RR024530	3294F07358	3-20X25X2 3-16X25X2
CU#3A	CARRIER	38AQ012520	2694F03167	2-AP43 BELTS
CU#3B	CARRIER	38AQ012520	2694F03133	
AHU#4	CARRIER	40RR016540	1794F93527	3-20X25X2
CU#4	CARRIER	38AQS016-530		
AHU#5	CARRIER	40RR012550	1694F92740	3-20X20X2
CU#5	CARRIER	38AQ012520	2694F03168	

HAMILTON MILL LIBRARY
 3690 BRASELTON HWY
 Dacula, GA 30019

AHU-1	TRANE	MCCB030UAOAOUA	KO9D83652A	2 - 12X24X2 6 - 24X24X2 2 - 24X12X12 85% BOX MERV 13 6 - 24X24X12 85% BOX MERV 13 1 - 5VX740
CU-1	TRANE	RHUCC404B203A0D0000005	CO9D14392	
DSSC-1		DUCTLESS MINI SPLIT		
ERV-1	VENMAR	ERV3000E PF1XG32SNHE		4 - 16X20X2
PIU UNITS				19 - 16X20X1
HUM-1	DRI-STEAM	STEAM HUMIDIFIER		
EF-1		IN-LINE		DIRECT DRIVE
EF-2		ROOF CENTRIFUGAL		DIRECT DRIVE
EF-3		ROOF CENTRIFUGAL		DIRECT DRIVE
EF-4		ROOF CENTRIFUGAL		DIRECT DRIVE
EF-5		ROOF CENTRIFUGAL		1-A48
EWH-1	QMARK	VESTIBULE		
EUH-1	QMARK	MECH ROOM		

GA Dept. of Drivers Services
310 Hurricane Shoals Road
Lawrenceville, GA 30045

AHU#1	TRANE	LPCAD08D1D0R T002026AA	T04E27778	2-20X25X2
HPU#1	TRANE	TWA120A300FA	4204R5DAD	1-B36 BELT
AHU#2	TRANE	LPCAD08D1D0R T002026AA	T04E27777	2-20X25X2
HPU#2	TRANE	TWA120A300FA	4204YFEAD	1-B36 BELT
AHU#3	TRANE	LPCAD08D1D0R T002026AA	T04E27776	2-20X25X2
HPU#3	TRANE	TWA120A300FA	4204J7SAD	1-B36 BELT
AHU#4	TRANE	TWE048C140C0	H1951HB26	1-20X20X1
APU#4	TRANE	2TWA0048A3000AB	31311W03F	
AHU#5	TRANE	TWE060D150B0	4191J561V	1-20X20X1
HPU#5	TRANE	2TWA0060A300AB	34815C72F	
AHU#6	TRANE	TWE060D150B0	4195NW61V	1-20X20X1
APU#6	TRANE	2TWA0060A300AB	343766M2F	

Snellville Tag Office
2845 Lenora Church Road
Snellville, GA 30078

FC-T1	LENNOX	G40VH60D13511	5905L30066	1-20X20X1
CU#1	LENNOX	HS2906013Y	5806G15985	
FC-T2	LENNOX	G40VH60D13511	5905L30062	1-20X20X1
CU#2	LENNOX	HS2906013Y	5806G15950	
FC-T3	LENNOX	G40VH60D13511	5905M22147	1-20X20X1
CU#3	LENNOX	HS2906013Y	5806G15987	
UNIT#4	MITSUBISHI	PLA36AA	52A00279B	WASHABLE
CU#4	MITSUBISHI	PUZA36NHA	52000156B	410A REFRIGERANT

Gwinnett County Airport Admin. Bldg.
600 Briscoe Blvd.
Lawrenceville, GA 30045

AHU#1	CARRIER	FB4BNF060	2203A7190A	1-20X20X1
CU#1	CARRIER	38YCC060320	2903E02627	
AHU#2	CARRIER	FB4BNF038	1403A70597	1-20X20X1
CU#2	CARRIER	38YCC048320	1803E28862	
AHU#3	CARRIER	FB4BNF042	1503A61209	1-20X20X1
CU#3	CARRIER	38YCC03634D	2003E01723	
AHU#4	CARRIER	FBFBNF042	2303E2942B	1-20X20X1
CU#4	CARRIER	38YCC042340	2003E2942B	
UH#1	Sterling	GAS FIRED	TF-200	
UH#2	Sterling	GAS FIRED	TF-200	
UH#3	Sterling	GAS FIRED	TF-200	
UH#4	Sterling	GAS FIRED	TF-200	

**Gwinnett County Airport Tower
590 Briscoe Blvd.
Lawrenceville, GA 30045**

AHU#1	CARRIER	FEMX4300B	A132169291	1-16X25X1
CU#1	COMFORTMAKER	NXH530KA100	E130510403	
AHU#2	CARRIER	FEMX4360B	A133170959	1-16X25X1
CU#2	COMFORTMAKER	NXH536GKA100	E133110507	
AHU#3	CARRIER	FB4CNP036	5014A69609	1-20X20X1
CU#3	CARRIER	25HCE43A310	1715E18105	
AHU#4	CARRIER	FEM4X600B	A138287240	1-16X25X1
CU#4	COMFORTMAKER	NXH560GKA100	E134217701	

**Peachtree Corners Tag Office (Rental)
6135 Peachtree Parkway, suite 201-B
Norcross, GA 30092**

RTU#1	CARRIER	50TFFU12-511	2203G21913	
MINI SPLIT	NA	NA	NA	

DOT District 3 Maint. Barn
425 Hoke O'Kelley Mill Rd., S.E.
Loganville, GA 30052

UH#1		GAS		
UH#2		GAS		
UH#3		GAS		
THROUGH THE WALL UNIT			WASHABLE FILTER	
EF#1	NA		NA	BELT

DOT District 5 Maint. Barn
4115 Arcadia Ind. Circle
Lilburn, GA 30047

UH#1		GAS		
UH#2		GAS		
UH#3		GAS		
THROUGH THE WALL UNIT			WASHABLE FILTER	
EF#1	NA		NA	BELT

BUFORD HUMAN SERVICES CENTER
2755 SAWNEE AVENUE
BUFORD, GA

RTU #1	TRANE	YCD180B4H0DE	L33104601D	4 - 20 X 20 X 2 4 - 16 X 20 X 2 1 - BX60
RTU #2	TRANE	Y0330A4HB1A5C01	J96G91237	16 - 20 X 20 X 2 1 - BX103
RTU #3	TRANE	YCD330A4HB1A5C01	J96G91238	16 - 20 X 20 X 2 1 - BX100
RTU #4	TRANE	YCD330A4HB1A5C01	J96G91239	16 - 20 X 20 X 2 1 - BX100
EF - 1				Direct drive
TEF - 2				Direct drive
TEF - 4				Direct drive
TEF - 5				Direct drive
KEF - 1				Direct drive
MINI SPLIT#1	NA	NA	NA	NA

GWINNETT COUNTY CORRECTIONS COMPLEX
750 HI HOPE ROAD
LAWRENCEVILLE, GA 30043

RTU #1	TRANE	YCD090C4LABE	Z25102221D	3 - 16X25X2 1 - AX45
RTU #2	TRANE	YCH120C4MOAC	Z41100658D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #3	TRANE	YCD060C4H0BF	Z15100879D	4 - 16X25X2
RTU #4	TRANE	YCH120C4MOAC	Z41100582D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #5	TRANE	YCH120C4MOAC	Z41100641D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #6	TRANE	YCH120C4MOAC	Z26101289D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #7	TRANE	YCH120C4MOAC	Z25102230D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #8	TRANE	YCD060C4H0BF	Z04101893D	4 - 16X25X2 DIRECT DRIVE
RTU#9	TRANE	YCH120C4MOAC	Z25102190D	2 - 20X25X2 2 - 16X25X2 1 - BX51

RTU #10	TRANE	YCH120C4MOAC	Z25101394D	2 - 20X25X2 2 - 16X25X2 1 - BX51
RTU #11	TRANE	YHC102E4RYA0KF6	130412344L	2 - 20X25X2 DIRECT DRIVE
RTU #12	TRANE	YCD075C4LABE	Z27100434D	3 - 16X25X2 1 - AX45
RTU #13	TRANE	YCD090C4LABE	Z24102135	3 - 16X25X2 1 - AX44
RTU #14	TRANE	YCD090C4LABE	Z26100757D	3 - 16X25X2 1 - AX45
RTU #15	TRANE	SAHFC2040Y26A 4CD3001	C01E50784	12 - 20X20X2 1 - BX70 1 - AX62
RTU #16	TRANE	SAHFC2040Y26A 3BD3001	C01E50783	12 - 20X20X2 1 - BX64 1 - AX62
RTU #17	TRANE	YCD090C4LABE	Z24102098D	3 - 16X25X2 1 - AX44
RTU #18	TRANE	YCD090C4LABE	Z24100051D	3 - 16X25X2 1 - AX44
RTU #19	TRANE	YCD090C4LABE	Z23101650D	3 - 16X25X2 1 - AX44
RTU #20	TRANE	YCD090C4LABE	Z26102407D	3 - 16X25X2 1 - AX44
RTU #21	TRANE	YCD090C4LABE	Z23100840D	3 - 16X25X2

					1 - AX44
RTU #22	TRANE	YCD090C4LABE	Z23100734D	3 - 16X25X2	1 - AX44
RTU #23	TRANE	YCH120C4MOAC	Z41100673D	2 - 20X25X2	2 - 16X25X2
					1 - BX51
RTU #24	TRANE	TCC018F100BG	Z3833KH2H	1 - 20X20X1	DIRECT DRIVE
RTU #25	TRANE	YCC018F1LOBH	Z22503Y2H	1 - 20X20X1	DIRECT DRIVE
RTU #26	TRANE	YCC018F1LOGB	R073YX12H	1 - 20X20X1	DIRECT DRIVE
RTU #27	TRANE	YCC018F1LOGB	Z0243CS2H	1 - 20X20X1	DIRECT DRIVE
KITCHEN	YORK			10 - 20X25X2	2 - AX62
MUA #1	REZNOR			2 - 16X25X2	12 - 12X20X2
					2 - BX58
MUA #2	REZNOR			2 - 16X25X2	12 - 12X20X2
					2 - BX58
MUA #3	REZNOR			2 - 16X25X2	12 - 12X20X2
					2 - BX58
MUA #4	REZNOR			2 - 16X25X2	

12 - 12X20X2

2 - BX58

GWINNETT COUNTY CORRECTIONS COMPLEX
750 HI HOPE ROAD
LAWRENCEVILLE, GA 30043

EF #1	DIRECT DRIVE
EF #2	DIRECT DRIVE
EF #3	DIRECT DRIVE
EF #4	DIRECT DRIVE
EF #5	DIRECT DRIVE
EF #6	DIRECT DRIVE
EF #7	DIRECT DRIVE
EF #8	DIRECT DRIVE
EF #9	DIRECT DRIVE
EF #10	DIRECT DRIVE
EF #11	DIRECT DRIVE
EF #12	DIRECT DRIVE
EF #13	1 - AX32
EF #14	1 - AX32
EF #15	DIRECT DRIVE
EF #16	DIRECT DRIVE

EF #17	DIRECT DRIVE
EF #18	DIRECT DRIVE
EF #19	DIRECT DRIVE
EF #20	DIRECT DRIVE
EF #21	DIRECT DRIVE
EF #22	DIRECT DRIVE
EF #23	DIRECT DRIVE
EF #24	DIRECT DRIVE
EF #25	DIRECT DRIVE
EF #26	DIRECT DRIVE
EF #27	DIRECT DRIVE
EF #28	DIRECT DRIVE
EF #29	DIRECT DRIVE
EF #30	DIRECT DRIVE
EF #31	DIRECT DRIVE
EF #32	DIRECT DRIVE
EF #33	DIRECT DRIVE
EF #34	DIRECT DRIVE
EF #35	DIRECT DRIVE

EF #36			DIRECT DRIVE
EF #37			DIRECT DRIVE
EF #38			DIRECT DRIVE
EF #39			DIRECT DRIVE
EF #40			DIRECT DRIVE
EF #41			DIRECT DRIVE
EF #42			2 - AX60
EF #43			2 - AX43
EF #44			2 - AX60
EF #45			2 - AX60
EF #46			DIRECT DRIVE
EF #47			1 - AX28
EF #48			1 - 4L180
EF #49			1 - AX21
EF #50			1 - AX21
HP #1	TRANE	1-1/2 TON SPLIT HP	
HP #2	TRANE	THRU THE WALL	
HP #3	TRANE	THRU THE WALL	

GWINNETT COUNTY DOT MAINTENANCE AND SUPPLY
 FACILITY 620 WINDER HWY
 LAWRENCEVILLE, GA 30045

AHU #1 YORK 12 - 16X20X2
 2 - AX48

CU #1 TRANE TTA240B400GA 14183KXCTA

AHU #2 YORK 30 - 16X20X2
 4 - BX68

CU #2 YORK YCUL0066EC46XCASD

CRU #1 LIEBERT 2 - 19X25X4
 2 - B55

CU #3 LIEBERT 7-1/2 TON
 EF #1 1 - 3L190

EF #2 1 - 3L380

EF #3 1 - 4L560

EF #4 1 - 4L560

EF #5 1 - AX26

EF #6 1 - A67

EF #7 1 - 4L430

EF #8 DIRECT DRIVE

EF #9 DIRECT DRIVE

EF #10

DIRECT DRIVE

EF#11

DIRECT DRIVE

EF #12

DIRECT DRIVE

Server Room

AHU

Goodman

ARUF24B14AA

1207142095

16X20X1

CU

Goodman

SSX140241BB

1206039924

**FLEET MANAGEMENT FACILITY
 620 SWANSON DRIVE
 LAWRENCEVILLE, GA 30043**

AHU #1	MAGIC AIRE	60BVW/BUX-A	990384337	2 - 16X25X2 1 - 4L450
HTR #1	REZNOR	HX100-8	EAYD65H5N 05739	
CU #1	CARRIER	38CKE060620	1999E14152	
AHU #2	MAGIC AIRE	60BVW/BUX-A	990384328	2 - 16X25X2 1 - 4L450
HTR #2	REZNOR	HX100-8	EAYD65H5N 05740	
CU #2	CARRIER	38CKC048620	1299E21955	
AHU #3	MAGIC AIRE	60BVW/BUX-A	990384336	2 - 16X25X2 1 - 4L450
HTR #3	REZNOR	HX100-8	EAYD65H5N 05741	
CU #3	CARRIER	38CKC048620	1299E21961	
AHU #4	MAGIC AIRE	60BVW/BUX-A	990384327	2 - 16X25X2 1 - 4L450
HTR #4	REZNOR	HX100-8	EAYD65H5N 05738	
CU #4	CARRIER	38CK060620	1999E14149	
AHU #5	CARRIER	40RM0016-B006HC	0899F00679	8 - 15-5/8X21-

EF #15			1 - A39
EF #16			1 - A39
EF #17			1 - A39
EF #18			1 - A39
EF #19			1- 4L210
EF #20			2 - 4L290
EF #21			2 - A30
EF #22			2 - A30
EF #23			DIRECT DRIVE
EF #24			1-A43
EF #25			1 - A33

**GOVERNMENT ANNEX
750 SOUTH PERRY STREET
LAWRENCEVILLE, GA 30046**

AHU #1	CARRIER	60 TON AHU	20 - 20X25X2 4 - 16X25X2 3 - B80
CU #1	CARRIER	38AH064---6-DA 1703F28549	
AHU #2	CARRIER	60 TON AHU	20 - 20X25X2 4 - 16X25X2 3 - B80

CU #2	CARRIER	38AH064---6-DA	1703F28556	
EF #1	COOK	90aceh90c15dh	050SF55359-00/0007808	Direct Drive
EF #2	FLO AIRE INC			Direct Drive

MINI SPLIT

CU #1	FUJITSU	AOU9RL2	EXN006997
AHU#1	FUJITSU	ASU9RL2	EXA011239
CU #2	MITSUBISHI	PUY-A12NHA	55U03558C
AHU#2	MITSUBISHI	PLA-A12BAG	54A00319C

PIU		43-15.5X17.5X1
PIU		1-16X20X1
PIU		1-20X20X1
PIU		14-17X19X1
PIU		1-20X20X1

**GWINNETT HISTORIC COURT HOUSE
 185 CROGAN STREET
 LAWRENCEVILLE, GA 30046**

AHU B-1	CARRIER	39LA1033BA1131-L	329IT18242	2 - 25X24X4 1 - BX32
---------	---------	------------------	------------	-------------------------

AHU B-2	CARRIER	39LD1063GL1131-R	329IT18241	2 - 20X22X2 2 - AX34
---------	---------	------------------	------------	-------------------------

AHU 2-1	CARRIER	39ED08	3091T32022	2 - 24X24X4 1 - 16X24X4 1 - BX38
---------	---------	--------	------------	--

AHU 2-2	CARRIER	39ED08	3091T32196	2 - 24X24X4 1 - 16X24X4 1 - BX38
---------	---------	--------	------------	--

AHU 2-3	CARRIER	39LB1031GC1121-L	2591T17549	2 - 16X20X4 1 - AX26
---------	---------	------------------	------------	-------------------------

RTU 2	CARRIER	39ER11	269IT32004	3 - 24X25X4 1 - BX38
-------	---------	--------	------------	-------------------------

RTU 1	CARRIER	38ER08	269IT3002	3 - 24X24X4 1 - BX38
-------	---------	--------	-----------	-------------------------

FC #1	CARRIER			1 - 16X20X1
-------	---------	--	--	-------------

FC #2	CARRIER			1 - 16X20X1
-------	---------	--	--	-------------

HWP-1

CHWP -1

EF #1

DIRECT DRIVE

EF #2

DIRECT DRIVE

LAWRENCEVILLE SENIOR CENTER
 70 BENSON STREET
 LAWRENCEVILLE, GA 30045

RTU #2	TRANE	2FF00000000200C	634101275L	4 - 16X25X2 1 - AX32
RTU #1	TRANE	YCD210B4L0BC	111210259D	4 - 20X20X2 4 - 20X25X2 1 - BX75
RTU #4	TRANE	YSC072E4R6A12000000000000C	111210629L	4 - 16X25X2 1 - AX32
RTU #3	TRANE	YSC072E4RLA12000000000000C	H401424930	4 - 16X25X2 1 - AX32
RTU #5	TRANE	4YCC3030A1075AA	11115JS69H	1 - 14X16X1 DIRECT DRIVE
RTU #6	TRANE	YSC060E4RLA18000000000000B	111111381L	2 - 20X25X2 1 - AX26
RTU #7	TRANE	1PD000C1B00200A	515102413L	2 - 20X25X2 DIRECT DRIVE
FA #1	PENN	MU-4015		1 - A55
VENT - 1	PASER RAF	FMX24BFT		1 - 4L320

GWINNETT SENIOR SERVICES CENTER
567 SWANSON DRIVE
LAWRENCEVILLE, GA 30043

ERV - 1	Energy Recovery System	Penn Barry M:56M2002xM33	S:20103300189	12 - 16 X 25 X 2
FCU - 1	DAIKIN			1 - 16 X 25 X 2
FCU - 2	DAIKIN			1 - 16 X 25 X 2
FCU - 3	DAIKIN			1 - 16 X 25 X 2
FCU - 4	DAIKIN			1 - 16 X 25 X 2
FCU - 5	DAIKIN			1 - 16 X 25 X 2
FCU - 6	DAIKIN			1 - 16 X 25 X 2
FCU - 7	DAIKIN			1 - 16 X 25 X 2
FCU - 8	DAIKIN			1 - 16 X 25 X 2
FCU - 9	DAIKIN			1 - 16 X 25 X 2
FCU - 10	DAIKIN			1 - 16 X 25 X 2
FCU - 11	DAIKIN			1 - 16 X 25 X 2
FCU - 12	DAIKIN			1 - 16 X 25 X 2
DSFC - 1	M:FAQ24PVJV/S:E000248 2009.9	DUCTLESS SPLIT DSCU-1	M:RZQ24PVJV S;4000333	2009.8 610A
DSFC - 2	M:FTXS2411VJU/S:E002501 2010.1	DUCTLESS SPLIT DSCU-2	M;RXS24DVJU S:E004823	2010.2 610A
HP - 1	DAIKIN	RXYQ120PYDN	S;A000545	MADE;2009 12 610A

EH-1 Q-MARK

HP -2 DAIKIN M:RXYQ72PYDN S:A000381 MADE:2009/ 07 610A EXHAUST FAN PENN BARRY
M:N/A S:N/A

PHASE II

DWEF LOREN COOK M:101ACRU 101R15D S:050SE71630-00/0000701

KEF-1 CAPTIVE AIRE M:NCA18FA JOB:1631023 06/24/2013
(866)784-6900

KEF-2 CAPTIVE AIRE -11- -11- -11-

Fan#4 DIRECT M:A2-D250-G15 JOB#:1631023 6/27/2013
INDUSTRIAL
AIR HEATER
(KMAU-2) CAPTIVE
AIRE.COM
800-334-9256

KMAU-1 11 11 11 11
Fan#3

AAON M:RN-015-3-0-E603-3G9 S:201308-ANGL 30528 15 Ton.
MAU-1 Part # 131930

HP DAIKIN M:REMQ96PBYD S:A001057 2013.2 410A

HP DAIKIN M:REMQ120PBYD S:A001966 2013.1 410A

HP DAIKIN M:REMQ120PBYD S:A001964 2013.1 410A

11 FCUS DAIKIN IN ADDITION

FCU1	DAIKIN	2 - 20X20X4
FCU2	DAIKIN	WASHABLE
FCU3	DAIKIN	WASHABLE
FCU4	DAIKIN	WASHABLE
FCU5	DAIKIN	WASHABLE
FCU6	DAIKIN	2 - 20X20X4
FCU7	DAIKIN	WASHABLE
FCU8	DAIKIN	WASHABLE
FCU9	DAIKIN	2 - 20X20X4
FCU10	DAIKIN	2 - 20X20X4
FCU11	DAIKIN	WASHABLE

PIU UNITS

39 - 12X12X1

GWINNETT CENTRAL SERVICES
455 GRAYSON HWY
LAWRENCEVILLE, GA 30046

PIU UNITS

73 - 20X20X1

HUM-1 DRI-STEAM

45LB/HR

HUM-2 DRI-STEAM

45LB/HR

ONE JUSTICE SQUARE
446 W. CROGAN STREET
LAWRENCEVILLE, GA 30046

RTU #1	TRANE	SEHFC704QT66C9AD 3001A0D00000L00 RT0Y8600	C99H15019M	35 - 16X20X2 2 - BX91
--------	-------	---	------------	--------------------------

RTU #2	TRANE	SEHFC704QT66C9AD 3001A0D00000L00 RT0Y8600	C99H15018M	35 - 16X20X2 2 - BX91
--------	-------	---	------------	--------------------------

RTU #3	TRANE	SEHFC704QT66C9AD 3001A0D00000L00 RT0Y8600	C99H15020M	35 - 16X20X2 2 - AX92
--------	-------	---	------------	--------------------------

RTU #4	TRANE	SEHFC704QT66C9AD 3001A0D00000L00 RT0Y8600	C99H15013M	35 - 16X20X2 2 - BX91
--------	-------	---	------------	--------------------------

AHU #1	TRANE			1 - 20X20X1
--------	-------	--	--	-------------

CU #1	TRANE			
-------	-------	--	--	--

AHU #2	TRANE			1 - 20X20X1
--------	-------	--	--	-------------

CU #2	TRANE			
-------	-------	--	--	--

AHU #3	TRANE			1 - 20X20X1
--------	-------	--	--	-------------

CU #3	TRANE			
-------	-------	--	--	--

AHU #4	TRANE			1 - 20X20X1
--------	-------	--	--	-------------

CU #4	TRANE			
-------	-------	--	--	--

EF #1

1 - AX51

PIU

27 - 12X14X1

UNITS

41 - 14X16X1

GWINNETT COUNTY POLICE HEADQUARTERS

**750 HI HOPE
ROAD
LAWRENCEVILLE,
GA 30043**

RTU#3A	York	TCA150520N	5604B03922	4 - 18x24x2	BX51
RTU #2	CARRIER	48TCDD12A2G6A0A0A0	4610G20631	4-20x20x2	Ax49
RTU #3	TRANE	YHC092E4RLA0EC0C	114211282L	2 - 20x30xX2 3 - 20x25x2	Direct drive
RTU #4	TRANE	YSD210F4RLB00YJ	144210680D	8-20x20x2	Bx75
RTU #5	TRANE	YSC090F4RLA08C	144211482L	4- 16x25x2	Ax32
RTU #6	TRANE	YHC092E4RLA0EC0C1A 1B0B000E	114211272L	2 - 20x30xX2 3 - 20x25x2	Direct drive
RTU #7	CARRIER	48TCDD12A2G6A0A0A0	0310G50474	4-20x20x2	Ax49
RTU #8	YORK	DM150N15P4AAA4A	NOA8543923	4 - 20X25X2	1 - BX56
RTU #9	TRANE	YSD150F4RHA003G*06	152110264D		
RTU #10	TRANE	YSD150F4RHA003G*06	152110282D		
RTU #11	CARRIER	48TMD012-601	0204G40504	4-20x20x2	Ax49
RTU #12	TRANE	YHC120E4RLA0MC0C 1A100B0000000E0000	132010272L	2 - 20x30xX2 3 - 20x25x2	Direct drive
RTU #13	TRANE	YHC072E4RLA0LD0C 1A100B0000000D0000	132011776L	6-16x20x2	Ax35
RTU #14	TRANE	YHC072E4RLA0RC0C 1A1B0B0000000D000	134710705L	4 - 20X25X2	Ax35
RTU #15	TRANE	YSC090F4RHA003G*06	152012388L		
RTU #16	TRANE	YSC072F4RHA003G*06	152012244L		

RTU #17	TRANE	YSC048E4RLA1SC	144211436L	2-20x30x2	Ax26
RTU #18	TRANE	YHC048E4RMA16A0C	132010019L	4 - 16X24X2	Ax29
RTU #19	TRANE	4YCC3024B1064BA	14404P829H	Filter grille	Direct drive
RTU#20	TRANE	YHC120E4RMA0FC DC1A1B0B000E	114212215L	2 - 20x30xX2 3 - 20x25x2	Direct drive
RTU#21	CARRIER	48TMD014A601	1604G20681	4 - 20x20x2	Bx47
RTU #22	AAON	RM01030AB02144M 000U0B0HD00BRJAA0 B0000A000000B	200311- AMEJ00727	6-16x20x2	Bx59

MINI SPLIT UNITS

1	DSS-	DAIKIN RXS12JEVJU	C002635		
2	DSS-	DAIKIN RXS12JEVJU	C002928		
3	DSS-	DAIKIN RXS12JEVJU	C002637		
4	DSS-	DAIKIN RXS24DVJU	E006501		
FUJITSU		A0U36CLX1	HBN017442		

POLICE ANNEX AND 911 CENTER
 770 HI HOPE ROAD
 LAWRENCEVILLE, GA 30043

AHU #1	YORK				16-24X24X4 8-12X24X4 16-24X24X12 HEPA 8-12X24X12 HEPA 6 - CX72
--------	------	--	--	--	--

AHU #2	TEMPTROL	WF-DH4	T001835-001-00		1 - 24X24X2 1 - 24X24X12 BOX MERV 13
--------	----------	--------	----------------	--	--

AHU #3	TEMPTROL	WF-DH3	T001835-002-00		1 - 24X24X2 1 - 24X24X12 BOX MERV 13
--------	----------	--------	----------------	--	--

PCWP-1	ARMSTRONG				
--------	-----------	--	--	--	--

PCWP-2	ARMSTRONG				
--------	-----------	--	--	--	--

PCWP-2	ARMSTRONG				
--------	-----------	--	--	--	--

PCWP-3	ARMSTRONG				
--------	-----------	--	--	--	--

DCWP-1	ARMSTRONG				
--------	-----------	--	--	--	--

DCWP-2	ARMSTRONG				
--------	-----------	--	--	--	--

FC-1	JOHNSON CONTROLS				DIRECT DRIVE
------	------------------	--	--	--	--------------

FC-2	JOHNSON CONTROLS				DIRECT DRIVE
------	------------------	--	--	--	--------------

UH-1	TPI				
------	-----	--	--	--	--

EF-1	COOK	1200MX1200MX	0508064945-01	1-AX40
EF-2	COOK	1500MX1500MX	050S064945-01	1-AX45
EF-3	COOK	1200MX1200MX	050SC64945-01	1-AX39
HUM-1	DRI-STEAM			45LB/HR
HUM-2	DRI-STEAM			45LB/HR
PIU UNITS	JOHNSON CONTROLS			33-14X24X1 14-17X30X1
PAC-1	LIEBERT	VS053DMA000306A	C09F8E0159	6-20X25X4 2- LIEBERT 181030P3
CU -1	LIEBERT	CDF205-A	0925C21381	
PAC-2	LIEBERT	VS053DMA000306A	C09F8E0160	6-20X25X4 2- LIEBERT 181030P3
CU -2	LIEBERT	CDF205-A	0925C21387	
PAC-3	LIEBERT	VS053DMA000306A	C09F8E0140	6-20X25X4 2- LIEBERT 181030P3
CU -3	LIEBERT	CDF205-A	0920C20784	
PAC-4	LIEBERT	VS053DMA000306A	C09F8E0139	6-20X25X4 2- LIEBERT 181030P3
CU -4	LIEBERT	CDF205-A	0925C21357	
PAC-5	LIEBERT	VS053DMA000306A		6-20X25X4 2- LIEBERT 181030P3

CU -5	LIEBERT	CDF205-A	0925C21373	
PAC-6	LIEBERT	VS053DMA000306A	C09F8E0141	6-20X25X4 2- LIEBERT 181030P3
CU -6	LIEBERT	CDF205-A	0925C21349	
PAC-7	LIEBERT	VS053DMA000305A	C09F8E0118	4-20X25X4 2- LIEBERT 181030P7
CU -7	LIEBERT	CDF165A	0924C21271	
PAC-8	LIEBERT	VS053DMA000305A	C09F8E0119	4-20X25X4 2- LIEBERT 181030P7
CU -8	LIEBERT	CDF165A	0924C21257	
PAC-9	LIEBERT	VS070DMA000305A	C09F8E0105	6-20X25X4 2- LIEBERT 181030P6
CU -9	LIEBERT	CDF308A	0925C21425	
PAC-10	LIEBERT	VS070DMA000305A	C09F8E0107	6-20X25X4 2- LIEBERT 181030P6
CU -10	LIEBERT	CDF308A	0925C21423	
PAC-11	LIEBERT	VS070DMA000305A	C09F8E0104	6-20X25X4 2- LIEBERT 181030P6
CU -11	LIEBERT	CDF308A	0925C21420	
PAC-12	LIEBERT	VS070DMA000305A	C09F8E0106	6-20X25X4 2- LIEBERT 181030P6

CU -12	LIEBERT	CDF308A	0925C21422	
PAC-13	LIEBERT	MMD60E7A00L0	0925N185710	2-20X20X4 1-LIEBERT B0570VT
CU -13	LIEBERT	PFH067A-AL7	0925N185771	
PAC-14	LIEBERT	MMD60E7A00L0	0925N185718	2-20X20X4 1-LIEBERT B0570VT
CU -14	LIEBERT	PFH067A-AL7	0925N185742	
PAC-15	LIEBERT	MMD60E7A00L0	0925N185752	2-20X20X4 1-LIEBERT B0570VT
CU -15	LIEBERT	PFH067A-AL7	0925N185134	

**POLICE WEST PRECINCT
6160 CRESCENT DRIVE
NORCROSS, GA 30071**

RTU #1	TRANE	YSC060A3RMA0000-150	335101210L	2 - 20X25X1 DIRECT DRIVE
RTU #2	TRANE	YCD150D3H0BA	341107730D	4 - 20X25X2 2 - 20X20X2 1 - BX62
RTU #3	TRANE	YSC072A3R1A1-0..C	337100296L	4 - 16X25X2 1 - AX32
RTU #4	TRANE	YCP030F1M0AB	31552281H	2 - 20X20X2 DIRECT DRIVE
RTU #5	TRANE	YSC072A3RLA000010-C	339100189L	4 - 16X25X2 1 - AX32

RTU #6	TRANE	YCC024F1L0BH	3341YEN2H	2 - 20X20X2 DIRECT DRIVE
HTR-1				1 - 16X20X1
EF - 1	GREENHECK	DX11B		1 - 4L250
EF - 2	GREENHECK			DIRECT DRIVE
EF - 3	GREENHECK			DIRECT DRIVE

**POLICE SOUTH PRECINCT
2273 ALCOVY ROAD
DACULA, GA 30019**

Facility has Roof Top Units

PAHU#1	CARRIER	48TJD008-511GA	0998G30034	4- 16X20X2 1 - AX48
PAHU#2	CARRIER	48TJD008-511GA	0998G30036	4- 16X20X2 1 - AX48
PAHU#3	CARRIER	48TJD009-511	0998G30197	4- 16X20X2 1 - AX48
EF - 1	GREENHECK	DX11B		1 - 4L240
EF - 2	GREENHECK	CEILING		DIRECT DRIVE
HTR -1	MARKEL			N/A

**POLICE NORTH PRECINCT
2735 MALL OF GEORGIA BOULEVARD
BUFORD, GA 30518**

FURN-1	TRANE	TUD040C924K4	50642TT1G	1 - 14X25X1
CU - 1	TRANE	2TTB2018A1000AA	51435BX3F	
FURN-2	TRANE	TUD040C924K4	50642TR1G	1 - 14X25X1
CU - 2	TRANE	TTB024C100AZ	51545875F	
FURN-3	TRANE	TUD040C930K4	50823KH1G	1 - 14X25X1
CU - 3	TRANE	2TTA0030A3000AA	5034W1M3F	
FURN-4a	TRANE	TUD080C948K4	50335Y71TG	1 - 20X25X1
FURN - 4b	TRANE	TUD080C948K4	5041MTN1G	1 - 16X25X1
CU - 4	TRANE	TTA096A300FA	5143T27AD	
FURN-5	TRANE	TUD100C960K4	4471RGA1G	1 - 14X25X1
CU - 5	TRANE	2TTA0060A3000AA	5045TE23F	
FURN-6	TRANE	TUD040C930K4	5031MRE1G	1 - 14X25X1
CU - 6	TRANE	2TTA0030A3000AA	5095TE53F	
FURN-7	TRANE	TUD100C960K4	4352Y81G	1 - 20X25X1
CU - 7	TRANE	2TTA0060A3000AA	5095TA23F	
FURN-8	TRANE	TUD100C960K4	448311W1G	1 - 20X25X1
CU - 8	TRANE	2TTA0060A3000AA	5095TCH3F	

FURN-9	TRANE	TUD060C936K4	4352Y81G	1 - 14X25X1
CU - 9	TRANE	2TTA003000AA	5034WWN3F	
FURN-10	TRANE	TUD040C930K4	5031MRF1G	1 - 14X25X1
CU -10	TRANE	2TTA0036A3000AA	4402T3FEF	
FURN-11	TRANE	TUD100C960K4	448311R1G	1 - 20X25X1
CU -11	TRANE	2TTA0060A3000AA	5095TE53F	
FURN-12	TRANE	TUD100C960K4	4472TES1G	1 - 20X25X1
CU - 12	TRANE	2TTA0060A3000AA	5154WDK3F	
EF - 1	GREENHECK	SP-117 CABINET		N/A
EF - 2	GREENHECK	SP-117 CABINET		N/A
EF - 3	GREENHECK	G-140-B ROOF		DIR. DRIVE
EF - 4	GREENHECK	G -70-E ROOF		DIR DRIVE
EF - 5	GREENHECK	SP - 117 CABINET		N/A
EF - 6	GREENHECK	SP - 117 CABINET		N/A
EF - 7	GREENHECK	SP - 117 CABINET		N/A
EF - 8	GREENHECK	G -130- C ROOF		DIR DRIVE
EF - 9	GREENHECK	CUE-101B ROOF		DIR DRIVE
GUH- 1	REZNOR	F - 75		
ECH- 1	MARKEL	3480		

**POLICE EAST PRECINCT
2273 ALCOVY ROAD
DACULA, GA 30019**

Facility has a Boiler, Cooling Tower, Pump and Eleven Water Source Heat Pumps

WSHP #1	CARRIER	50RHR060BCC50130	0506V25776	1 - 20X25X1 1 - 16X20X1
WSHP #2	CARRIER	50RHR036ECC51130	0506V25922	1 - 18X25X1
WSHP #3	CARRIER	50RHR036ECC51130	0506V25767	2 - 18X18X1
WSHP #4	CARRIER	50RHR019ECC31130	0506V25885	1 - 16X20X1
WSHP #5	CARRIER	50RHR036SCC51130	0506V25920	1 - 18X25X1
WSHP #6	CARRIER	50RHR019BCC31130	0506V25884	1 - 16X20X1
WSHP #7	CARRIER	50RHR030ECC51130	0506V25913	1 - 18X25X1
WSHP #8	CARRIER	50RHR060SCC50130	0506V25771	1 - 20X25X1 1 - 16X20X1
WSHP #9	CARRIER	50RHR024BCC51130	0506V25888	1 - 16X20X1
WSHP#10	CARRIER	50RHR048SCC50130	0206V25167	1 - 18X18X1
WSHP#11	CARRIER	50RHR036ZCC51130	0506V25917	1 - 18X25X1
BLR #1	RAY PACK	H3-0322 INPUT 320,000 BTU OUTPUT 269,000BTU	062246804	
CT #1	BALTIMORE AIR COIL	FXV-L421		

CT PUMP	BALDOR	655126	1-1/2 HP
PUMP #1	WEG	H3-0322	3 HP
MINI SPLIT			
EF - 1		IN LINE CENTRIFUGAL	BELT ??
EF - 2		SIDEWAL L	DIRECT
EF - 3		SIDEWAL L	DIRECT
EF - 4		IN LINE CENTRIFUGAL	BELT ??
UH - 1			ELECTRIC
UH - 2			ELECTRIC

POLICE CENTRAL PRECINCT
 3125 SATELLITE BLVD.
 DULUTH, GA 30096

RTU #1	CARRIER	48TFE006-501KB	5100G24446	2 - 16X25X2 1 - AP40
RTU #2	CARRIER	48TFE005-501KB	5100G24662	2 - 16X25X2 1 - AP36
RTU #3	CARRIER	48TFF004-501KB	5100G20442	2 - 16X25X2 1 - AP36
RTU #4	CARRIER	48TFE005-501KB	5100G24601	2 - 16X25X2 1 - AP36
RTU #5	CARRIER	48GS-030060501	5000G10349	2 - 12X20X1 DIR DRIVE
RTU #6	CARRIER	48GS-024060301	4600G10376	2 - 12X20X1 DIR DRIVE
RTU #7	CARRIER	48TFE006-501KB	5100G24445	2 - 16X25X2 1 - AP48
RTU #8	CARRIER	48TFE008-501KB	5100G34351	4 - 16X20X2 1 - AP48
EF - 1	GREENHECK	SP - 7 CEILING		DIRECT
EF - 2	GREENHECK	SP - 7 CEILING		DIRECT
EF - 3	GREENHECK	140-B ROOF		1 - 4L230
EF - 4	GREENHECK	G-70-B ROOF		DIRECT

**GWINNETT ANIMAL SHELTER
884 WINDER HWY
LAWRENCEVILLE, GA 30045**

RTU #1	TRANE	YHC092A3RMA2HHOC	706102818L	2 - 20X25X2 1 - AX35
RTU #2	TRANE	YHC043A3RMA13A0C	706102754L	2 - 20X25X2 1 - AX26
RTU #3	TRANE	YHC03A3RMA13AOC	7061028341	2 - 20X25X2 1 - AX26
RTU #4	TRANE	YHC03A3RLA120C	7061028561	2 - 20X25X2 1 - AX26
RTU #5	TRANE	YHC033A3RMA120H	7061029122	2 - 20X25X2 1 - AX26
RTU #6	TRANE	2YCC3024A104AA	70745B89H	1 - 20X25X1 DIR DRIVE
RTU #7	TRANE	YHC033A3RLA120C	761027761	2 - 20X25X2 1 - AX26
RTU #8	TRANE	4YCC3018A1040AA	70713Y79H	1 - 20X25X1
RTU #9	TRANE	4YC03018A1040AA	6374W019H	1 - 20X25X1
RTU #10	TRANE	4YC03018A1040AA	637424B9H	1 - 20X25X1
RTU #11	TRANE	4YCC3018A1040AA	6433K1B9H	1 - 20X25X1
RTU #12	TRANE	YH092A3RMA2HA0C	7061028961	2 - 20X25X2 1 - AX35

RTU #13	TRANE	YHC102A3RMA2GH0C	7061031281	4 - 20X25X2 1 - AX35
RTU #14	TRANE	2YCC30301064AA	7031WGC9H	1 - 20X25X1 DIR DRIVE
RTU #15	TRANE	2YCC3030A10464AA	70310B29H	1 - 20X25X1 DIR DRIVE
RTU #16	TRANE	2YCC3030A1064AA	702437B9H	1 - 20X25X1 DIR DRIVE
RTU #17	TRANE	4YCC3018A1040AA	7062XG59H	1 - 20X25X1 DIR DRIVE
RTU #18	TRANE	4YCC3018A1040AA	7045PRS9H	1 - 20X25X1 DIR DRIVE
RTU #19	TRANE	4YCC3018A1040AA	7034NLS9H	1 - 20X25X1 DIR DRIVE
RTU #20	TRANE	4YCC3024A1040AA	70731SD9H	1 - 20X25X1 DIR DRIVE
RTU #21	TRANE	4YCC3024A1040AA	7074N8H9H	1 - 20X25X1 DIR DRIVE
RTU #22	TRANE	2YCC3030A1040AA	7063WEN9H	1 - 20X25X1 DIR DRIVE
RTU #23	TRANE	YHC092A3RMA2HH0C	7061027381	4 - 20X25X2 1 - AX35
RTU #24	TRANE	4YCC3018A1040AA	36433NNG9H	1 - 20X25X1 DIR DRIVE
RTU #25	TRANE	4YCC3018A1040AA	7045KTM9H	1 - 20X25X1

				DIR DRIVE
RTU #26	TRANE	4YCC3018A1040AA	37071MAE9H	1 - 20X25X1 DIR DRIVE
ERU #1	AAON	RN-013-8-0-EA09-3F4 201110-ANGK18450		8 - 14X25X2 2 - A55
ERU #2	AAON	RN-010-8-0-EB09-3K4 201110-ANGJ18456		4 - 20X20X2 2 - A49
AHU-1	TRANE	TWE060A300L	7075UNLBD	2 - 16X20X1 1 - AX44
CU - 1	TRANE	2TWA3060A3000AA	6511RXW2F	

**POLICE TRAINING COMPLEX
854 WINDER HWY
LAWRENCEVILLE, GA 30045**

TRAINING BUILDING

AHU #1	McQUAY			MERV 13 85% 6 - 24 X 24 X 4 2 - 12 X 24 X 4 2 - 5VX470 2 - BX47
AHU #2	McQUAY			MERV 13 85% 3 - 20 X 24 X 4 2 - BX34 2 - BX40
AHU #3	McQUAY			MERV 13 85% 4 - 24 X 24 X 4 4 - 20 X 24 X 4 3 - BX40

MERV 14 95%
18 - 24X24X22
HEPA
18 - 24X24X11.5
6 - 24X12X11.5

No. 9 Carrier 5 ton package Electric ??

AHU #8 McQUAY MERV 13 85%
6 - 24 X 24 X 4
2 - BX45
1 - BX42

BLR-1 CLEAVER BROOKS WATER TUBE MTF-2500

BLR-2 CLEAVER BROOKS WATER TUBE MTF-2500

**GEORGIA STATE PATROL
1645 PLEASANT HILL ROAD
DULUTH, GA 30096**

UNIT #1 CARRIER 48TCDD08A2A5AOAOAO 0213G10027 4-16X20X2
1 - A52

**PRIME RADIO TOWER
374 HICKORY DRIVE
LAWRENCEVILLE, GA 30046**

UNIT #1	TRANE	TCC3060A1000AA	7243WJ29H	2-24X24X1
UNIT #2	TRANE	TCC3060A1000AA		2-24X24X1

**BROWN RADIO TOWER
1850 N. BROWN ROAD
LAWRENCEVILLE, GA 30043-8120**

UNIT #1	TRANE	4TCC3060A1000AA	7243X3D9H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	724336C9H	2-24X24X1
UNIT #3	BARD	WH242-A04	140H021739253-02	1 -16X25X1

**TRIBBLE RADIO TOWER
2568 CHANDLER ROAD, SE
LAWRENCEVILLE, GA 30045**

UNIT #1	TRANE	4TCC3060A1000AA	7262HP89H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	7262HF69H	2-24X24X1

**GOSHEN RADIO TOWER
5878 GOSHEN SPRINGS ROAD
NORCROSS, GA 30071-3509**

UNIT #1	TRANE	4TCC3060A1000AA	72613RC9H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	7261YPG9H	2-24X24X1

**LANIER MOUNTAIN RADIO TOWER
2286 HIGHPOINT ROAD
SNELLVILLE, GA 30078-3144**

UNIT #1	TRANE	4TCC3060A1000AA	7265NN09H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	7261JK59H	2-24X24X1

**TUGGLE RADIO TOWER
3800 TUGGLE ROAD
BUFORD, GA 30519-4039**

UNIT #1	TRANE	4TCC3060A1000AA	7265YX49H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	7264M0R9H	2-24X24X1

**WATER PARK RADIO TOWER
2601 BUFORD DAM ROAD
BUFORD, GA 30518-2040**

UNIT #1	TRANE	4TCC3060A1000AA	7321K0F9H	2-24X24X1
UNIT #2	TRANE	4TCC3060A1000AA	72613RA9H	2-24X24X1

HEADQUARTERS RADIO TOWER
770 HI HOPE ROAD
LAWRENCEVILLE, GA 30043-4540

UNIT #1	BARD	AVP36ACA050N-100	HU-F000112010-000- 017	1	-21-1/2X36-1/2X2
UNIT #2	BARD	AVP36ACA050N-100	HU-F000112010-000- 018	1	-21-1/2X36-1/2X2
UNIT #3	BARD	AVP36ACA050N-100	HU-F000112010-000- 019	1	-21-1/2X36-1/2X2
UNIT #4	BARD	AVP36ACA050N-100	HU-F000112010-000- 013	1	-21-1/2X36-1/2X2