

October 22, 2021

ADDENDUM #3
BL106-21, Duncan Creek Synthetic Turf Replacement

QUESTIONS AND ANSWERS:

The following is being issued to provide clarification and answer questions received.

- Q1. On page 22 of the specs, there is a drawing list which shows a C-302 drawing. This drawing was not included in the provided drawing set, can this be provided?
- A1. Sheet C-302 has been eliminated from the drawing set. Please disregard.**
- Q2. What turf manufacturer installed the existing field? What is the existing infill type/mix?
- A2. The existing field is a Field Turf Product. The existing infill appears to be 100% rubber. Contractor shall field verify.**
- Q3. On page 43 of the specifications several mockups are required including 200SF stone swale assembly, seat wall in plaza center & 500SF of entry/plaza concrete. As these items are not specifically included in our scope of work, are these mockups truly a requirement?
- A3. Please disregard this section. No mockups are required for the performance of this project.**
- Q4. In the description of alternates, the scope for Alternate #2 requires a minimum face weight of 48oz yet in the turf specifications, the scope for Alternate #2 requires a minimum face weight of 46oz. Which is accurate?
- A4. The dual fiber product shall follow specifications section 32 97 20.**
- Q5. In the front end section of the specifications the Gmax testing is specified to be no greater than 120 at installation and no greater than 130 for life of warranty yet the turf specifications requires gmax tests to not exceed 110 at installation and no greater than 160 for life of warranty. Which is accurate?
- A5. The GMAX testing requirements shall follow specifications section 32 97 20.**
- Q6. The drawings show full soccer markings yet the specifications call for only soccer tick markings. Please confirm only soccer tick marks are desired.
- A6. All field markings shall follow specifications section 32 97 20.**
- Q7. The specifications require a permeability test to be performed by a licensed geotechnical engineer. Can this test be provided by a licensed 3rd party testing agency?
- A7. Yes**