



RE: Gwinnett County Department of Water Resources
Project Name: Lanier Filter Plant Chemical Addition and Sampling Improvements
Project Number: F-1382-08
Bid Number: BL001-23

ADDENDUM NO. 2 – January 18, 2023

TO: ALL PLAN-HOLDERS OF CONTRACT DOCUMENTS

General

1. This Addendum is being issued to provide the following revisions and/or clarifications to the bid documents and answers to the questions received.

Make the following changes/clarifications to the above referenced bid:

DATE CHANGES

Instructions on Submitting Questions:

Questions regarding bids should be submitted to Brittany Bryant, Purchasing Associate II at fax 770-822-8728, or email Brittany.Bryant@gwinnettcountry.com no later than 3:00 p.m. local time, **February 3, 2023**. Bids are legal and binding upon the bidder when submitted.

Questions Received

1. Please provide the plan holders list.
 - a. The current plan holders list is attached.
2. Spec section 099000 mentions painting of pvc piping. Spec section 400505 Pipe Schedule says pvc does not require coating. Please clarify if any of the pvc piping gets coated. Exposed or in Trench?
 - a. Exposed and trench installed PVC piping does not require coating.
3. Does the new precast trench or vaults require coating either on the inside or outside?
 - a. No, the proposed precast trenches and the proposed utility vaults do not require internal or external coating.

Attachments

- Planholders List

All bidders shall acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject bidder to disqualification. This addendum forms a part of the Contract Documents.

Planholders List

Date Updated 1/17/2023

Company Name	Type
Alberici	Contractor
Clark Construction	Contractor
Kiewit/Western Summit	Contractor
Construct Connect	Planhouse
Reeves Young	Contractor
P. F. Moon	Contractor
Dodge Construction Network	Planhouse
Haren Construction	Contractor
Lakeshore Engineering	Contractor
Heavy Constructors	Contractor
IHC Construction Companies LLC	Contractor