



January 19, 2023

ADDENDUM #2
BL006-23, Gwinnett Aquatic Center Improvements

QUESTIONS:

- Q1. With the tile replacement at Collins Hill, will the same size tile be used in the replacement?**
A1. Yes, the same size tile.
- Q2. For both Alternate #1 and Alternate #2, there is a tile ledge in the deep end of both pools. Is that to be replaced as well at Collins Hill?**
A2. Collins Hill is to have the white tile around the pool ledge and water line tile removed and replaced. Mountain Park is to have just any chipped or missing tiles removed and replaced.
- Q3. Could you clarify the expansion joint locations for Mountain Park? Are they existing or are they being installed?**
A3. The plans show where all expansion joints are located. They are existing.

Thank you,

Jake Scarpone

Jake Scarpone
Purchasing Associate