



January 24, 2023

Addendum 1
BL116-22, Purchase and Installation of Custom Park Signs on an Annual Contract

- Q1. Can you provide or direct me to the artwork for this project please?
A1. Please see the attached artwork and design standards. However, sign graphic colors may vary per order.
- Q2. On item 1 and 2: what size sleeve?
A2. 2.5" sleeve. The sleeve must fit the outside of the 2" tubing.
- Q3. Are we allowed to use 3 mm aluminum composite, on items 5 through 18, or does it have to be .090 aluminum?
A3. .090 aluminum should be used on items 5-18.
- Q4. On line items 32 and 33, where do we find details for 5.3a through 5.3e?
A4. Please see the attached design standards.

This addendum should be signed in the space provided below and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Thank you.

Lindsey Gravitt
Purchasing Associate II

Company Name _____

Authorized Representative _____