



February 16, 2024

Addendum No. 1
BL024-24
Ridge Road Pump Station Decommissioning - Phase 2

The following addition/changes modify the Bid No. BL024-24 "Ridge Road Pump Station Decommissioning - Phase 2" Contract Documents, dated January 2024, as first advertised on January 31, 2024.

I. Clarification:

C1. Low Pressure Air Testing will be required for the 24-inch diameter pipe in accordance with specification section 33 31 00, 3.15. The acceptable elapsed time in minutes/100 feet for the 24-inch diameter pipe shall be the same as for the 18-inch pipe diameter given in the table included in specification section 33 31 00, 3.15 A-6, which is 2.4 minutes/100 feet.

Low Pressure Air Testing remains in effect for smaller size piping as shown in the specifications.

II. Questions:

Q1. What is the engineers estimate for this project?

A1. There is approved funding for this project. Gwinnett County expects each contractor to bid a competitive price. Award will be made to the lowest responsive and responsible bidder.

Acknowledge receipt of this addendum on the firm information page of the request for proposal.
Sincerely,

Brittany Bryant, CPPB
Purchasing Associate III