



April 22, 2024

**Addendum No. 4
BL037-24
Hopkins Mill Subdivision Water Main Replacement**

The following addition/changes modify the Bid No. BL037-24 "Hopkins Mill Subdivision Water Main Replacement" Contract Documents, dated March 2024, as first advertised on March 20, 2024.

I. Questions:

Q1. What is the diameter of the water main?

A1. The diameter of the water main is 8-inches.

Acknowledge receipt of this addendum on the firm information page of the request for proposal.

Sincerely,

Brittany Bryant, CPPB
Purchasing Associate III