



July 23, 2025

**ADDENDUM #2  
BL079-25**

**Replacement of Odor Control Fans at the F. Wayne Hill Water Resources Center**

The following addition/changes modify the Bid No. BL079-25 "Replacement of Odor Control Fans at the F. Wayne Hill Water Resources Center" Contract Documents, dated June 2025, as first advertised on June 11, 2025.

**I. Questions:**

- Q1. The answer to question Q9 in addendum #1 brings up another question. The new fans will come with new motor base frames, so no problem there, but on the drawings it appears that the Inertia Bases are to be demoed as well. The fan manufacturers have stated that they would be able to be reused as long as we replace the inertia springs. Can you please clarify that the term "Motor Base Frame" does not include the inertia bases, because we will not be bidding the inertia bases as it is stated currently. This would add a substantial cost and a lot of time to the project.**
- A1. New equipment manufacturers may have different inertia base requirements than the existing. If the new equipment manufacturer states that the existing inertia bases are compatible with the new equipment, then the inertia bases can be reused as long as the manufacturer warrants it. At minimum the springs need to be replaced.**

Acknowledge receipt of this addendum on the bid form page (16) of the Notice to Bid.

Thank you,

Brittany Bryant, CPPB  
Purchasing Associate III