



July 28, 2025

**ADDENDUM #3  
BL079-25**

**Replacement of Odor Control Fans at the F. Wayne Hill Water Resources Center**

The following addition/changes modify the Bid No. BL079-25 "Replacement of Odor Control Fans at the F. Wayne Hill Water Resources Center" Contract Documents, dated June 2025, as first advertised on June 11, 2025.

**I. Questions:**

**Q1. It is our understanding that these are the sensors required for the new fans:**

**Sensors**

**DE Bearing Vertical Vibration  
DE Bearing Horizontal Vibration  
Motor Winding Temperature Switch  
ODE Bearing Vertical Vibration  
ODE Bearing Horizontal Vibration  
ODE Bearing Axial Vibration  
Base Vertical Vibration  
Base Horizontal Vibration  
Keyphasor Sensor**

**Please verify that all of these sensors are the same as what is currently being monitored, and that there is wiring in place for each of them so that no new wiring will be required from the motors to the MCC?**

**A1.** Only two vibration sensors and a temperature switch are being currently monitored. Contractors should plan to run conduits and wiring from the remaining sensors to the control panels.

Acknowledge receipt of this addendum on the bid form page (16) of the Notice to Bid.

Thank you,

Brittany Bryant, CPPB  
Purchasing Associate III