



January 27, 2026

ADDENDUM #1  
IWQ 121396, Purchase of Tilting Disc Check Valve

**\*\*\*QUOTE SUBMITTAL DEADLINE HAS BEEN POSTPONED UNTIL THURSDAY, JANUARY 29, 2026\*\*\***

**Questions**

- Q1. Will there be a map or a specified location that we can receive for this installation. The installation access is one of the most integral parts. I do see the address of South Waterworks Road but maybe County employee to reach or meet for viewing?**
- A1. No, installation or service of any kind will be provided. This is for the supply of a tilting disc check valve only. The South Waterworks Road address is for delivery only.
- Q2. For this quote request, are you all wanting an Air Cushion or a Lever & Weight Check Valve? The Lever & Weight Check Valve has a spring kit that would help regulate the open/close function on the disk during operation.**
- A2. The valve needs to have a bottom mounted hydraulic buffer to minimize hammer.
- Q3. Will an import valve be accepted?**
- A4. Please quote according to the specifications provided in the invitation to quote. Approved equivalents are acceptable, but they will not be evaluated until after quotes have been received.
- Q4. There seems to be conflict with compliance. Is this for a valve with a cast iron body or ductile iron?**
- A4. Per specifications, a cast iron body should be utilized.
- Q5. What are the delivery requirements?**
- A5. Delivery is freight on board destination, prepaid and allowed to:  
Gwinnett County Department of Water Resources  
2590 South Waterworks Road  
Buford, GA 30518  
Unit pricing in quotes should include in all charges, including but not limited to supply and delivery.
- Q6. References seem to be written around a construction project rather than the supply of materials. Please clarify the purpose for this form.**
- A6. This form is included in all solicitations to validate the supplier's credentials and ability to do business in a capacity that is similar in size or scope described in the invitation.
- Q7. Since the application is for a potable water system, are there any requirements for any type of coating OD/ID?**
- A7. Per specifications, the product quoted should include minimum six (6) millimeter coating.
- Q8. What is the estimated cost of the sixteen (16) inch check valve project? Also, what are the anticipated start and end dates?**
- A8. The County doesn't have a planned project cost currently. This is for the purchase of the valve described in the specifications only.

This addendum should be signed in the space provided below and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Company Name \_\_\_\_\_

Authorized Representative \_\_\_\_\_

Thank you,

*Jordan Mitchell*

Jordan Mitchell  
Purchasing Associate II