



April 29, 2026

ADDENDUM #2
BL069-26, Gwinnett County Sheriff's Office Fire Alarm Upgrade Project

****The bid deadline for BL069-26, Gwinnett County Sheriff's Office Fire Alarm Upgrade Project, has been rescheduled for Friday, May 8, 2026 at 2:50 PM. Any reference to the original bid date shall be replaced with May 4, 2026.**** Sealed bids will be received by the Gwinnett County Purchasing Division, 75 Langley Drive, Lawrenceville, Georgia 30046 until **2:50 P.M. local time on May 8, 2026**. The bid opening will be virtual ONLY. To access the bid opening, visit the following link (<https://gwinnettgov.webex.com/gwinnettgov/j.php?MTID=m5324d1eb36acc977c80450f24b25fba1>) or dial 1-408-418-9388 and enter Access Code 2348 407 6088. Bids will be publicly opened and read aloud at 3:00 P.M. Any bid received after 2:50 P.M. will not be accepted. Bid envelope should be marked on the outside with Bid Number, name of Bidder, date and time of opening. One unbound original and two (2) copies should be submitted.

QUESTIONS & ANSWERS:

- Q1. Regarding Addendum one that recently came out, the engineers answered question 4.13 by making the fire protection contractor responsible for providing any M.O. dampers in duct work and exhaust fans but didn't provide the locations and size of them per room. They revised drawing FA401 with a note for the rooms that are to be protected by clean agent system, "provide motor operated dampers in all ducts serving these rooms". Can you please identify any ducts in the room, including how many and the size?
- A1. Please see the attached revised drawings FA401.

This addendum should be acknowledged in the space provided on page 000410-03 of the bid documents and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Thank you,

Jake Scarpone

Jake Scarpone, CPPB
Purchasing Associate III

Attachments:

1. Drawings FA401

