



April 1, 2026

ADDENDUM #1
IWQ 128258, Purchase of Steel Risers

Questions:

- Q1. The invitation to quote identifies MJ Gate Valves in the description but the submittal, on page two (2), is for a Flanged Gate Valve. Please verify the connections on these Gate Valves. Should MJ connect to MJ, Flange connect to Flange, or Flange connect to MJ (tapping valve)?**
- A1. Valves must have an MJ X MJ connection.**

This addendum should be signed in the space provided below and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Company Name _____

Authorized Representative _____

Thank you,

Jordan Mitchell

Jordan Mitchell
Purchasing Associate II