



May 8, 2026

Addendum No. 1

BL078-26

Project No.: F01552.1 Brushy Fork Road (Rozena Place to Lilly Brook Drive)

DATE OF BID OPENING HAS CHANGED :

NEW TIME AND DATE: 3:00 PM LOCAL TIME, FRIDAY MAY 15, 2026

FOR THE CONTRACTORS' INFORMATION:

Q1. For Class 3 RCP (15" and 18") - In Drawing 22-0002 (from Structure B1 to B3), it shows a 15" RCP, while in the 13-003 plan set it shows an 18" RCP. Could you please confirm which size is correct and should be considered for bidding?

R1. The drainage design was checked, and these pipes have been designed as 15" pipes. Therefore, it is a labeling issue on the 13-series plan sheet. The two pipes should be considered as 15".

All bidders shall acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject the bidder to disqualification. This addendum forms a part of the Contract Documents.

You should acknowledge receipt on Page I-4 of the bidding documents.

Thank you.

**Michael Milstein
Purchasing Associate II**