



May 15, 2026

ADDENDUM #1
IWQ 128186, Purchase of Fire Hoses

Questions

- Q1. Please provide information about what type of ends/fittings are required.**
A1. The hose needs to have male x female ends/fittings.
- Q2. Are there any requirements for color? Would yellow or clear coat white be acceptable?**
A2. Clear coat white is acceptable.
- Q3. What will this item be used for? Is it being used in life saving efforts or as a mill hose in plant or landscape trucks?**
A3. These hoses are used for everyday street cleaning, landscaping, etc.
- Q4. Please provide the brand/model that is currently in use.**
A4. FLEXTRAL, Part #BWA35150NSTER050AL. Per the invitation, approved equivalents will be accepted.
- Q5. What material type and thread are required for the couplings?**
A5. Hard coat aluminum.
- Q6. Please provide the required length.**
A6. 50 feet.
- Q7. What type of fittings are required? Should they be brass or alum rocker lug or pin lung?**
A7. NH/NST (Fire Hose Threads).
- Q8. Should the hoses be single-jacket or double-jacket?**
A8. Single Jacket Polyester.
- Q9. What material is required?**
A9. Durable woven polyester.
- Q10. Can product specs be submitted before the deadline for evaluation of equivalency?**
A10. If quoting an equivalent, please submit specs and other relevant information with your quote submittal. Evaluations of equivalency will be made after quotes are submitted.

This addendum should be signed in the space provided below and returned with your bid. Failure to do so may result in your bid being deemed non-responsive.

Company Name _____

Authorized Representative _____

Thank you,

Anna West
Purchasing Associate II